

Certificate of Compliance

This is to certify that

EDGE ANALYTICAL, Inc.,
An Accredited Drinking Water Laboratory,
Certification number 046, has completed the analysis of

DRINKMORE WATER/DRINKMORE DELIVERY INC
“Purified Water”

on December 13, 2024, according to the FDA testing requirements for bottled drinking water.
All parameters were found to be in compliance with 21 CFR 165 and 21 CFR 129
published limits for bottled drinking water.



A handwritten signature in blue ink that reads "Pat Miller".

Deputy QA Officer
24-29410



Burlington, WA Corporate Laboratory (a)
 1620 S Walnut St - Burlington, WA 98233 - 800.755.9295 • 360.757.1400
 Bellingham, WA Microbiology (b)
 805 Orchard Dr Ste 4 - Bellingham, WA 98225 - 360.715.1212

Portland, OR Microbiology/Chemistry (c)
 9725 SW Commerce Cr Ste A2 - Wilsonville, OR 97070 - 503.682.7802
 Corvallis, OR Microbiology/Chemistry (d)
 1100 NE Circle Blvd, Ste 130 - Corvallis, OR 97330 - 541.753.4946
 Bend, OR Microbiology (e)
 20332 Empire Blvd Ste 4 - Bend, OR 97701 - 541.639.8425

BOTTLED WATER STANDARD OF QUALITY REPORT

Client Name: Drinkmore Water/Drinkmore Delivery Inc
 7595 Rickenbacker Drive
 Gaithersburg, MD 20879

Reference Number: **24-29410**

Authorized by:

Pat Miller
 Patrick Miller, MS
 Deputy QA Officer

Project: 50 State Product - Purified Water

Field ID: 50 State Product

Sample Description: Purified Water

Sampled By:

Sample Date: 10/02/2024

Lab Number: **56744**

Report Date: 12/13/2024

Sampled Comment: 5 G

Approved By: anp,bj,dcs,ebvp,ljh,ma,mc
 s,nml,pdm

Inorganic Chemicals (IOCs)

| CAS ID# | COMPOUNDS | RESULT | SOQ | MRL | Units | Method | Lab | COMMENT |
|------------|----------------------------|--------|-------|--------|-------|-------------|-----|---------|
| 57-12-5 | CYANIDE | ND | 0.2 | 0.005 | mg/L | OIA-1677-DW | a | |
| 7440-36-0 | ANTIMONY | ND | 0.006 | 0.001 | mg/L | 200.8 | a | |
| 7440-38-2 | ARSENIC | ND | 0.010 | 0.001 | mg/L | 200.8 | a | |
| 7440-39-3 | BARIUM | ND | 1.0 | 0.001 | mg/L | 200.8 | a | |
| 7440-41-7 | BERYLLIUM | ND | 0.004 | 0.001 | mg/L | 200.8 | a | |
| 7440-43-9 | CADMIUM | ND | 0.005 | 0.001 | mg/L | 200.8 | a | |
| 7440-47-3 | CHROMIUM | ND | 0.05 | 0.001 | mg/L | 200.8 | a | |
| 16984-48-8 | FLUORIDE | ND | 2 | 0.10 | mg/L | 300.0 | a | |
| 7439-92-1 | LEAD | ND | 0.005 | 0.001 | mg/L | 200.8 | a | |
| 7439-97-6 | MERCURY | ND | 0.001 | 0.0002 | mg/L | 200.8 | a | |
| 7440-02-0 | NICKEL | ND | 0.1 | 0.001 | mg/L | 200.8 | a | |
| 14797-55-8 | NITRATE-N | 0.12 | 10 | 0.10 | mg/L | 300.0 | a | |
| 14797-65-0 | NITRITE-N | ND | 1.0 | 0.10 | mg/L | 300.0 | a | |
| E-10128 | TOTAL NITRATE+NITRITE as N | 0.12 | 10 | 0.10 | mg/L | 300.0 | a | |
| 7782-49-2 | SELENIUM | ND | 0.010 | 0.005 | mg/L | 200.8 | a | |
| 7440-28-0 | THALLIUM | ND | 0.002 | 0.001 | mg/L | 200.8 | a | |

Notation:

A Result of "ND" indicates that the compound was not detected above the Lab's Reporting Limit - MRL.
 SOQ - Standard of Quality, maximum permissible level of a contaminant in water established by CBWA, IBWA or US FDA.
 MRL - Method Reporting Limit .

If you have any questions concerning this report contact us at the above phone number.

BOTTLED WATER STANDARD OF QUALITY REPORT

Secondary Inorganic Parameters

| CAS ID# | COMPOUNDS | RESULT | SOQ | MRL | Units | Method | Lab | COMMENT |
|------------|------------------------------|--------|-------|-------|-------|----------|-----|---------|
| 7429-90-5 | ALUMINUM | ND | 0.2 | 0.010 | mg/L | 200.7 | a | |
| 16887-00-6 | CHLORIDE | 1.7 | 250 | 0.1 | mg/L | 300.0 | a | |
| 7440-50-8 | COPPER | ND | 1.0 | 0.005 | mg/L | 200.8 | a | |
| 7439-89-6 | IRON | ND | 0.3 | 0.050 | mg/L | 200.7 | a | |
| 7439-96-5 | MANGANESE | ND | 0.05 | 0.001 | mg/L | 200.8 | a | |
| 7440-22-4 | SILVER | ND | 0.025 | 0.001 | mg/L | 200.8 | a | |
| 14808-79-8 | SULFATE | 0.6 | 250 | 10 | mg/L | 300.0 | a | |
| E-10173 | TOTAL DISSOLVED SOLIDS (TDS) | 10 | 500 | 10 | mg/L | SM2540 C | a | |
| 7440-66-6 | ZINC | ND | 5.00 | 0.005 | mg/L | 200.8 | a | |

Notation:

A Result of "ND" indicates that the compound was not detected above the Lab's Reporting Limit - MRL.
 SOQ - Standard of Quality, maximum permissible level of a contaminant in water established by CBWA, IBWA or US FDA.
 MRL - Method Reporting Limit .

BOTTLED WATER STANDARD OF QUALITY REPORT

Volatile Organic Chemicals (VOCs)

| CAS ID# | COMPOUNDS | RESULT | SOQ | MRL | Units | Method | Lab | COMMENT |
|-----------|--------------------------------|--------|------|-----|-------|--------|-----|---------|
| 75-35-4 | 1,1 - DICHLOROETHYLENE | ND | 2 | 0.5 | ug/L | 524.2 | a | |
| 71-55-6 | 1,1,1 - TRICHLOROETHANE | ND | 30 | 0.5 | ug/L | 524.2 | a | |
| 79-00-5 | 1,1,2 - TRICHLOROETHANE | ND | 5 | 0.5 | ug/L | 524.2 | a | |
| 107-06-2 | 1,2 - DICHLOROETHANE | ND | 2 | 0.5 | ug/L | 524.2 | a | |
| 78-87-5 | 1,2 - DICHLOROPROPANE | ND | 5 | 0.5 | ug/L | 524.2 | a | |
| 120-82-1 | 1,2,4 - TRICHLOROBENZENE | ND | 9 | 0.5 | ug/L | 524.2 | a | |
| 71-43-2 | BENZENE | ND | 1 | 0.5 | ug/L | 524.2 | a | |
| 56-23-5 | CARBON TETRACHLORIDE | ND | 2 | 0.5 | ug/L | 524.2 | a | |
| 156-59-2 | CIS - 1,2 - DICHLOROETHYLENE | ND | 70 | 0.5 | ug/L | 524.2 | a | |
| 156-60-5 | TRANS - 1,2 - DICHLOROETHYLENE | ND | 100 | 0.5 | ug/L | 524.2 | a | |
| 100-41-4 | ETHYLBENZENE | ND | 700 | 0.5 | ug/L | 524.2 | a | |
| 75-09-2 | DICHLOROMETHANE | ND | 3 | 0.5 | ug/L | 524.2 | a | |
| 108-90-7 | MONOCHLOROBENZENE | ND | 50 | 0.5 | ug/L | 524.2 | a | |
| 95-50-1 | O - DICHLOROBENZENE | ND | 600 | 0.5 | ug/L | 524.2 | a | |
| 106-46-7 | P - DICHLOROBENZENE | ND | 75 | 0.5 | ug/L | 524.2 | a | |
| 100-42-5 | STYRENE | ND | 100 | 0.5 | ug/L | 524.2 | a | |
| 127-18-4 | TETRACHLOROETHYLENE | ND | 1 | 0.5 | ug/L | 524.2 | a | |
| 108-88-3 | TOLUENE | ND | 1000 | 0.5 | ug/L | 524.2 | a | |
| 79-01-6 | TRICHLOROETHYLENE | ND | 1 | 0.5 | ug/L | 524.2 | a | |
| 75-01-4 | VINYL CHLORIDE | ND | 2 | 0.5 | ug/L | 524.2 | a | |
| 1330-20-7 | XYLENES (TOTAL) | ND | 1000 | 0.5 | ug/L | 524.2 | a | |

Notation:

A Result of "ND" indicates that the compound was not detected above the Lab's Reporting Limit - MRL.
 SOQ - Standard of Quality, maximum permissible level of a contaminant in water established by CBWA, IBWA or US FDA.
 MRL - Method Reporting Limit .

BOTTLED WATER STANDARD OF QUALITY REPORT

Synthetic Organic Chemicals (SOCs)

| CAS ID# | COMPOUNDS | RESULT | SOQ | MRL | Units | Method | Lab | COMMENT |
|------------|--|--------|------|------|-------|--------|-----|-----------------------------|
| 94-75-7 | 2,4 - D | ND | 70 | 0.1 | ug/L | 515.4 | a | |
| 93-72-1 | 2,4,5 - TP (SILVEX) | ND | 10 | 0.2 | ug/L | 515.4 | a | |
| 16655-82-6 | 3-HYDROXYCARBOFURAN | ND | | 1.0 | ug/L | 531.2 | a | |
| 15972-60-8 | ALACHLOR | ND | 2 | 0.2 | ug/L | 525.2 | a | |
| 116-06-3 | ALDICARB | ND | | 1.0 | ug/L | 531.2 | a | |
| 1646-88-4 | ALDICARB SULFONE | ND | | 1.6 | ug/L | 531.2 | a | |
| 1646-87-3 | ALDICARB SULFOXIDE | ND | | 1.0 | ug/L | 531.2 | a | |
| 309-00-2 | ALDRIN | ND | | 0.1 | ug/L | 525.2 | a | |
| 1912-24-9 | ATRAZINE | ND | 3 | 0.1 | ug/L | 525.2 | a | |
| 50-32-8 | BENZO(A)PYRENE | ND | 0.2 | 0.02 | ug/L | 525.2 | a | |
| 23184-66-9 | BUTACHLOR | ND | | 0.1 | ug/L | 525.2 | a | |
| 63-25-2 | CARBARYL | ND | | 1.0 | ug/L | 531.2 | a | |
| 1563-66-2 | CARBOFURAN | ND | 40 | 0.9 | ug/L | 531.2 | a | |
| 57-74-9 | CHLORDANE | ND | 0.5 | 0.2 | ug/L | 508.1 | a | |
| 75-99-0 | DALAPON | ND | 200 | 1 | ug/L | 515.4 | a | |
| 103-23-1 | DI(2-ETHYLHEXYL)-ADIPATE | ND | 400 | 0.6 | ug/L | 525.2 | a | |
| 117-81-7 | DI(2-ETHYLHEXYL)-PHTHALATE | ND | 6 | 0.6 | ug/L | 525.2 | a | |
| 96-12-8 | 1,2-DIBROMO-3-CHLOROPROPANE (DBCP) | ND | 0.2 | 0.02 | ug/L | 504.1 | a | |
| 1918-00-9 | DICAMBA | ND | | 0.2 | ug/L | 515.4 | a | |
| 60-57-1 | DIELDRIN | ND | | 0.1 | ug/L | 525.2 | a | |
| 88-85-7 | DINOSEB | ND | 7 | 0.2 | ug/L | 515.4 | a | |
| 1746-01-6 | DIOXIN (2,3,7,8-TETRACHLORODIBENZO-P-DIOXIN) | ND | 30 | 5 | pg/L | 1613 | | Analyzed by PACE_MN |
| 85-00-7 | DIQUAT | ND | 20 | 0.4 | ug/L | 549.2 | a | |
| 145-73-3 | ENDOTHALL | ND | 100 | 9 | ug/L | 548.1 | a | |
| 72-20-8 | ENDRIN | ND | 0.2 | 0.01 | ug/L | 525.2 | a | |
| 106-93-4 | 1,2 - DIBROMOETHANE (EDB) | ND | 0.05 | 0.02 | ug/L | 504.1 | a | |
| 96-18-4 | 1,2,3 - TRICHLOROPROPANE | ND | 0.03 | 0.02 | ug/L | 504.1 | a | |
| 1071-83-6 | GLYPHOSATE | ND | 700 | 6 | ug/L | 547 | a | |
| 76-44-8 | HEPTACHLOR | ND | 0.4 | 0.04 | ug/L | 525.2 | a | |
| 1024-57-3 | HEPTACHLOR EPOXIDE "B" | ND | 0.2 | 0.02 | ug/L | 525.2 | a | |
| 118-74-1 | HEXACHLOROBENZENE | ND | 1 | 0.1 | ug/L | 525.2 | a | |
| 77-47-4 | HEXACHLOROCYCLO-PENTADIENE | ND | 50 | 0.1 | ug/L | 525.2 | a | |
| 58-89-9 | LINDANE (BHC - GAMMA) | ND | 0.2 | 0.02 | ug/L | 525.2 | a | |
| 16752-77-5 | METHOMYL | ND | | 1.0 | ug/L | 531.2 | a | |
| 72-43-5 | METHOXYCHLOR | ND | 40 | 0.1 | ug/L | 525.2 | a | |
| 51218-45-2 | METOLACHLOR | ND | | 0.1 | ug/L | 525.2 | a | |
| 21087-64-9 | METRIBUZIN | ND | | 0.1 | ug/L | 525.2 | a | |
| 23135-22-0 | OXAMYL (VYDATE) | ND | 200 | 2 | ug/L | 531.2 | a | |
| 87-86-5 | PENTACHLOROPHENOL | ND | 1 | 0.04 | ug/L | 515.4 | a | |
| 1918-02-1 | PICLORAM | ND | 500 | 0.1 | ug/L | 515.4 | a | |
| 1336-36-3 | POLYCHLORINATED BIPHENYLS (PCBs) | ND | 0.5 | 0.5 | ug/L | 508.1 | a | |
| 1918-16-7 | PROPACHLOR | ND | | 0.1 | ug/L | 525.2 | a | |
| 122-34-9 | SIMAZINE | ND | 4 | 0.07 | ug/L | 525.2 | a | |
| 8001-35-2 | TOXAPHENE | ND | 3 | 1 | ug/L | 508.1 | a | |
| E-10253 | TOTAL PHENOLIC COMPOUNDS | ND | 1 | 1 | ug/L | 420.4 | a | Analyzed by Eurofins Pom CA |

Notation:

A Result of "ND" indicates that the compound was not detected above the Lab's Reporting Limit - MRL.
 SOQ - Standard of Quality, maximum permissible level of a contaminant in water established by CBWA, IBWA or US FDA.
 MRL - Method Reporting Limit .

BOTTLED WATER STANDARD OF QUALITY REPORT

Perfluorinated Compounds

| CAS ID# | COMPOUNDS | RESULT | SOQ | MRL | Units | Method | Lab | COMMENT |
|-------------|--|--------|-----|-----|-------|--------|-----|-----------------------|
| 763051-92-9 | 11-CHLOROEICOSAFLUORO-3-OXAUNDECANE-1-SULFONATE | ND | | 2.0 | ng/L | 537.1 | | Analyzed by Pace - FL |
| 13252-13-6 | HEXAFLUOROPROPYLENE OXIDE DIMER (HFPO-DA/GENX) | ND | | 2.0 | ng/L | 537.1 | | |
| 919005-14-4 | 4,8-DIOXA-3H-PERFLUORONONANOIC ACID (DONA, ADONA) | ND | | 2.0 | ng/L | 537.1 | | |
| 756426-58-1 | 9-CHLOROHEXADECAFLUORO-3-OXANONANE-1-SULFONIC ACID (F-53B MAJOR) | ND | | 2.0 | ng/L | 537.1 | | |
| 2991-50-6 | N-ETHYLPERFLUORO-1-OCTANESULFONAMIDOACETIC ACID (NETFOSAA) | ND | | 2.0 | ng/L | 537.1 | | |
| 2355-31-9 | N-METHYLPERFLUORO-1-OCTANESULFONAMIDOACETIC ACID (NMEFOSAA) | ND | | 2.0 | ng/L | 537.1 | | |
| 375-73-5 | PERFLUOROBUTANESULFONIC ACID (PFBS) | ND | | 2.0 | ng/L | 537.1 | | |
| 335-76-2 | PERFLUORODECANOIC ACID (PFDA) | ND | | 2.0 | ng/L | 537.1 | | |
| 307-55-1 | PERFLUORODODECANOIC ACID (PFDOA) | ND | | 2.0 | ng/L | 537.1 | | |
| 375-85-9 | PERFLUOROHEPTANOIC ACID (PFHPA) | ND | | 2.0 | ng/L | 537.1 | | |
| 355-46-4 | PERFLUOROHEXANESULFONIC ACID (PFHXS) | ND | | 2.0 | ng/L | 537.1 | | |
| 307-24-4 | PERFLUOROHEXANOIC ACID (PFHXA) | ND | | 2.0 | ng/L | 537.1 | | |
| 375-95-1 | PERFLUORONONANOIC ACID (PFNA) | ND | | 2.0 | ng/L | 537.1 | | |
| 1763-23-1 | PERFLUOROOCTANESULFONIC ACID (PFOS) | ND | | 2.0 | ng/L | 537.1 | | |
| 335-67-1 | PERFLUOROOCTANOIC ACID (PFOA) | ND | | 2.0 | ng/L | 537.1 | | |
| 376-06-7 | PERFLUOROTETRADECANOIC ACID (PFTA) | ND | | 2.0 | ng/L | 537.1 | | |
| 72629-94-8 | PERFLUOROTRIDECANOIC ACID (PFTRDA) | ND | | 2.0 | ng/L | 537.1 | | |
| 2058-94-8 | PERFLUOROUNDECANOIC ACID (PFUnA) | ND | | 2.0 | ng/L | 537.1 | | |

Notation:

A Result of "ND" indicates that the compound was not detected above the Lab's Reporting Limit - MRL.
 SOQ - Standard of Quality, maximum permissible level of a contaminant in water established by CBWA, IBWA or US FDA.
 MRL - Method Reporting Limit .

BOTTLED WATER STANDARD OF QUALITY REPORT

Water Properties

| CAS ID# | COMPOUNDS | RESULT | SOQ | MRL | Units | Method | Lab | COMMENT |
|-----------|--------------------|--------|-----|------|------------|----------|-----|-----------------------------|
| 1332-21-4 | ASBESTOS | ND | 7 | | MFL>10um | 100.2 | | Analyzed by EMSL |
| E-10139 | HYDROGEN ION (pH) | 6.92 | | | pH Units | 150.1 | a | Temp (C) : 21.1 |
| NA | TASTE | ND | | 1 | FTN | SM2160 B | a | |
| NA | MBAS (Surfactants) | ND | | 0.10 | mg/L | SM5540 C | a | Analyzed By Eurofins Pom CA |
| E-11712 | COLOR | ND | 15 | 5 | COLOR UNIT | SM2120 B | a | pH:7 |
| E-11734 | ODOR | ND | 3 | 1 | TON | SM2150 | a | Temperature: 39.3 C |
| E-10617 | TURBIDITY | 0.10 | 1 | 0.10 | NTU | 180.1 | a | |

Notation:

A Result of "ND" indicates that the compound was not detected above the Lab's Reporting Limit - MRL.
 SOQ - Standard of Quality, maximum permissible level of a contaminant in water established by CBWA, IBWA or US FDA.
 MRL - Method Reporting Limit .

BOTTLED WATER STANDARD OF QUALITY REPORT

Radiological Contaminants

| CAS ID# | COMPOUNDS | RESULT | SOQ | MRL | Units | Method | Lab | COMMENT |
|------------|-------------|--------|-------|-------|-------|-------------|-----|---------------------|
| 12587-46-1 | GROSS ALPHA | ND | 15 | 0 | pCi/L | 900.0 | | Analyzed by PacePA |
| 12587-47-2 | GROSS BETA | ND | 50 | 0 | pCi/L | 900.0 | | |
| 13982-63-3 | RADIUM 226 | ND | | | pCi/L | 903.1 | | |
| 15262-20-1 | RADIUM 228 | ND | 5 | | pCi/L | 904.0 | | |
| 7440-61-1 | URANIUM | ND | 0.030 | 0.001 | mg/L | 200.8 | a | |
| 14859-67-7 | RADON | ND | | | pCi/L | SM7500-Rn B | | Analyzed by Pace-PA |

Notation:

A Result of "ND" indicates that the compound was not detected above the Lab's Reporting Limit - MRL.
 SOQ - Standard of Quality, maximum permissible level of a contaminant in water established by CBWA, IBWA or US FDA.
 MRL - Method Reporting Limit .

BOTTLED WATER STANDARD OF QUALITY REPORT

Additional Volatile Organic Chemicals (New York)

| CAS ID# | COMPOUNDS | RESULT | SOQ | MRL | Units | Method | Lab | COMMENT |
|-------------|------------------------------|--------|-----|-----|-------|--------|-----|---------|
| 542-75-6 | 1,3-DICHLOROPROPYLENE, TOTAL | ND | | 0.5 | ug/L | 524.2 | a | |
| 75-34-3 | 1,1 - DICHLOROETHANE | ND | | 0.5 | ug/L | 524.2 | a | |
| 563-58-6 | 1,1 - DICHLOROPROPENE | ND | | 0.5 | ug/L | 524.2 | a | |
| 630-20-6 | 1,1,1,2 - TETRACHLOROETHANE | ND | | 0.5 | ug/L | 524.2 | a | |
| 79-34-5 | 1,1,2,2 - TETRACHLOROETHANE | ND | | 0.5 | ug/L | 524.2 | a | |
| 87-61-6 | 1,2,3 - TRICHLOROBENZENE | ND | | 0.5 | ug/L | 524.2 | a | |
| 96-18-4 | 1,2,3 - TRICHLOROPROPANE | ND | | 0.5 | ug/L | 524.2 | a | |
| 95-63-6 | 1,2,4 - TRIMETHYLBENZENE | ND | 21 | 0.5 | ug/L | 524.2 | a | |
| 142-28-9 | 1,3 - DICHLOROPROPANE | ND | | 0.5 | ug/L | 524.2 | a | |
| 108-67-8 | 1,3,5 - TRIMETHYLBENZENE | ND | | 0.5 | ug/L | 524.2 | a | |
| 594-20-7 | 2,2 - DICHLOROPROPANE | ND | | 0.5 | ug/L | 524.2 | a | |
| 108-86-1 | BROMOBENZENE | ND | | 0.5 | ug/L | 524.2 | a | |
| 74-97-5 | BROMOCHLOROMETHANE | ND | | 0.5 | ug/L | 524.2 | a | |
| 74-83-9 | BROMOMETHANE | ND | | 0.5 | ug/L | 524.2 | a | |
| 75-00-3 | CHLOROETHANE | ND | | 0.5 | ug/L | 524.2 | a | |
| 74-87-3 | CHLOROMETHANE | ND | | 0.5 | ug/L | 524.2 | a | |
| 10061-01-5 | CIS - 1,3 - DICHLOROPROPENE | ND | | 0.5 | ug/L | 524.2 | a | |
| 74-95-3 | DIBROMOMETHANE | ND | | 0.5 | ug/L | 524.2 | a | |
| 75-71-8 | DICHLORODIFLUOROMETHANE | ND | | 0.5 | ug/L | 524.2 | a | |
| 87-68-3 | HEXACHLOROBUTADIENE | ND | | 0.5 | ug/L | 524.2 | a | |
| 98-82-8 | ISOPROPYLBENZENE | ND | | 0.5 | ug/L | 524.2 | a | |
| 541-73-1 | M - DICHLOROBENZENE | ND | | 0.5 | ug/L | 524.2 | a | |
| 179601-23-1 | M/P - XYLENE | ND | | 0.5 | ug/L | 524.2 | a | |
| 1634-04-4 | METHYL TERT-BUTYL ETHER | ND | | 0.5 | ug/L | 524.2 | a | |
| 104-51-8 | N - BUTYLBENZENE | ND | | 0.5 | ug/L | 524.2 | a | |
| 103-65-1 | N - PROPYLBENZENE | ND | | 0.5 | ug/L | 524.2 | a | |
| 91-20-3 | NAPHTHALENE | ND | 14 | 0.5 | ug/L | 524.2 | a | |
| 95-49-8 | O - CHLOROTOLUENE | ND | | 0.5 | ug/L | 524.2 | a | |
| 106-43-4 | P - CHLOROTOLUENE | ND | | 0.5 | ug/L | 524.2 | a | |
| 95-47-6 | O - XYLENE | ND | | 0.5 | ug/L | 524.2 | a | |
| 99-87-6 | P - ISOPROPYLTOLUENE | ND | | 0.5 | ug/L | 524.2 | a | |
| 135-98-8 | SEC - BUTYLBENZENE | ND | | 0.5 | ug/L | 524.2 | a | |
| 98-06-6 | TERT - BUTYLBENZENE | ND | | 0.5 | ug/L | 524.2 | a | |
| 10061-02-6 | TRANS- 1,3 - DICHLOROPROPENE | ND | | 0.5 | ug/L | 524.2 | a | |
| 75-69-4 | TRICHLOROFLUOROMETHANE | ND | | 0.5 | ug/L | 524.2 | a | |

Notation:

A Result of "ND" indicates that the compound was not detected above the Lab's Reporting Limit - MRL.
 SOQ - Standard of Quality, maximum permissible level of a contaminant in water established by CBWA, IBWA or US FDA.
 MRL - Method Reporting Limit .

BOTTLED WATER STANDARD OF QUALITY REPORT

Additional Inorganic Chemicals (New York)

| CAS ID# | COMPOUNDS | RESULT | SOQ | MRL | Units | Method | Lab | COMMENT |
|---------|-------------|--------|-----|-----|------------|----------|-----|---------|
| E-11778 | HARDNESS | ND | | 10 | mg CaCO3/L | 200.7 | a | |
| E-14506 | ALKALINITY | 4.1 | | 1 | mg CaCO3/L | SM2320 B | a | |
| NA | CORROSIVITY | -4.47 | | | SI | SM203 | a | |

Notation:

A Result of "ND" indicates that the compound was not detected above the Lab's Reporting Limit - MRL.
 SOQ - Standard of Quality, maximum permissible level of a contaminant in water established by CBWA, IBWA or US FDA.
 MRL - Method Reporting Limit .

BOTTLED WATER STANDARD OF QUALITY REPORT**Inorganic Chemicals (Massachusetts)**

| CAS ID# | COMPOUNDS | RESULT | SOQ | MRL | Units | Method | Lab | COMMENT |
|-----------|-------------|--------|-----|------|-------|--------|-----|-----------------------------|
| 1497-73-0 | PERCHLORATE | ND | 2 | 0.50 | ug/L | 331.0 | a | Analyzed by Eurofins Pom CA |

Notation:

A Result of "ND" indicates that the compound was not detected above the Lab's Reporting Limit - MRL.
SOQ - Standard of Quality, maximum permissible level of a contaminant in water established by CBWA, IBWA or US FDA.
MRL - Method Reporting Limit .



Burlington, WA Corporate Laboratory (a)
 1620 S Walnut St - Burlington, WA 98233 - 800.755.9295 • 360.757.1400
Bellingham, WA Microbiology (b)
 805 Orchard Dr Ste 4 - Bellingham, WA 98225 - 360.715.1212

Portland, OR Microbiology/Chemistry (c)
 9725 SW Commerce Cr Ste A2 - Wilsonville, OR 97070 - 503.682.7802
Corvallis, OR Microbiology/Chemistry (d)
 1100 NE Circle Blvd, Ste 130 - Corvallis, OR 97330 - 541.753.4946
Bend, OR Microbiology (e)
 20332 Empire Blvd Ste 4 - Bend, OR 97701 - 541.639.8425

Data Report

Client Name: Drinkmore Water/Drinkmore Delivery Inc
 7595 Rickenbacker Drive
 Gaithersburg, MD 20879

Reference Number: **24-29410**
 Project: 50 State Product - Purified Water

Report Date: 12/13/24

Date Received: 9/30/24

Approved by: anp,bj

Authorized by:

Patrick Miller, MS
 Deputy QA Officer

| Sample Description: 50 State Product Purified Water | | | | | | | | Matrix BP | Sample Date: 10/2/24 10:40 am | | | |
|---|--------------------------------------|---------------------|-------|---------|-----------|-----|----------------------|---------------|-------------------------------|---------|----------------|---------|
| Lab Number: 56744 | | Sample Comment: 5 G | | | | | | Collected By: | | | | |
| CAS ID# | Parameter | Result | PQL | MDL | Units | DF | Method | Lab | Analyzed | Analyst | Batch | Comment |
| 7440-42-8 | BORON | ND | 0.050 | 0.006 | mg/L | 1.0 | 200.7 | a | 10/8/24 | BJ | 200.7_241008A5 | |
| 7440-70-2 | CALCIUM | 0.5 | 0.5 | 0.006 | mg/L | 1.0 | 200.7 | a | 10/8/24 | BJ | 200.7_241008A5 | |
| 7439-95-4 | MAGNESIUM | ND | 0.5 | 0.001 | mg/L | 1.0 | 200.7 | a | 10/8/24 | BJ | 200.7_241008A5 | |
| 7440-23-5 | SODIUM | 2.6 | 0.5 | 0.3 | mg/L | 1.0 | 200.7 | a | 10/8/24 | BJ | 200.7_241008A5 | |
| 7440-09-7 | POTASSIUM | ND | 1.0 | 0.06 | mg/L | 1.0 | 200.7 | a | 10/8/24 | BJ | 200.7_241008A5 | |
| 24959-67-9 | BROMIDE | ND | 0.005 | 0.00019 | mg/L | 1.0 | 300.1 | a | 10/8/24 | TJL | 300.1_241007A | |
| E-10184 | ELECTRICAL CONDUCTIVITY | 15.9 | 10 | | uS/cm | 1.0 | SM2510 B | a | 10/3/24 | CJK2 | EC_241003R | |
| | TOTAL COLIFORM For Taste Test | ABSENT | P/A | | per 100mL | 1.0 | SM9223 B/Colilert-18 | a | 10/3/24 | SPM2 | M_241002BUR | |

Notes:

ND = Not detected above the listed practical quantitation limit (PQL) or not above the Method Detection Limit (MDL), if requested.
 PQL = Practical Quantitation Limit is the lowest level that can be achieved within specified limits of precision and accuracy during routine laboratory operating conditions.
 D.F. - Dilution Factor

If you have any questions concerning this report contact us at the above phone number.